

Dorset Fire & Rescue Service

The Joint Emergency Services Building, Wimborne Road, Poole BH15 2BP

Direct Line: 01305 753008 Switchboard: (01305) 252600 Fax: (01305) 753100
www.dorsetfire.gov.uk



Paul Williams
Managing Director
Euro Compliance Ltd
90 Milton Avenue
Barnet
Herts
EN5 2EU

Your ref:
My ref: 00462022
Ask For: Andy Davis
Date: 17 April 2013

Dear Mr Williams

Regulatory Reform (Fire Safety) Order 2005
Address of Premises: Youell Court, 13A Belle Vue Road,
Bournemouth, BH6 3DA

Following your previous correspondence with Bruce Lockwood, Station Manager Underhill and I visited the above premises on 20/03/2013 to ascertain the effectiveness of the Way Guidance system. I am pleased to advise you that the system provides a satisfactory level of lighting and will meet the requirements of the Fire Safety Order. The visit was not an audit of all fire safety matters but looked into the specifics of the way guidance system.

Yours sincerely

Andy Davis
Fire Safety Officer



INVESTOR IN PEOPLE

Darran Gunter • Chief Fire Officer

