

# EMERGENCY LIGHTING COMPLETION CERTIFICATE

<u>Address:</u>	<b>Youell Court Bornemouth Dorset BH6 3DA</b>
Installation type:	EverGlow® Hi 150
Date installed:	24 <sup>th</sup> August 2012
Installation fitter:	R Davies
Issued:	28 <sup>th</sup> August 2012

## Declaration of Conformity

Euro Compliance Limited hereby declare that the EverGlow® emergency lighting system installation, or part thereof, at the above premises conforms, to the best of our knowledge and belief, to the appropriate recommendations given in;

- European Standard DIN 67 510 certified photoluminescent product
- BS 5266-1:2011, Emergency lighting – Part 1: (system design)
- BS 5266-6:1999 Emergency lighting – Part 6: (code of practice for non-electrical low mounted way guidance systems)
- CIBSE Fire Guide E, Fire Safety Engineering, 3<sup>rd</sup> edition 2010, 7.8.4

The system provides compliant emergency lighting and illumination of adequate intensity, as required by the Regulatory Reform Fire Safety Order 2005, Article 14.(2).(h), which states;

*“emergency routes and exits requiring illumination must be provided with emergency lighting of adequate intensity in the case of failure of their normal lighting”*

Signed for and on behalf of EURO COMPLIANCE LIMITED



Phil Williams  
Operations Director



Members of the Institute of Fire Engineers

**EURO COMPLIANCE LIMITED**  
90 Milton Avenue, Barnet, Herts, EN5 2EU Tel: 020 8440 2398 mailto: info@eurocompliance.co.uk

*Emergency  
Lighting  
Completion  
Certificate*